

Declaration of Performance

LE/DoP-Nr. 002E/CPR/2013-06-14

1. **Unique identification of the product type:** Mechanically operated locks
2. **Serial.-Nr.:** 1052 / 1042
3. **Intended use:** fire and/or smoke control doors
4. **Manufacturer:** Glutz Ltd.
Segetzstrasse 13
CH-4502 Solothurn
Switzerland
5. **Authorised representative:** ./.
6. **Systems of assessment of constancy of performance:** System 1
7. **Harmonised standard:** EN 12209: 2003 + AC: 2006
8. **Notified body:** itb Warszawa NB-Nr. 1488 has issued the EC Certificate of conformity with the number 1488-CPD-0284/W issued to system 1 and essential characteristics assessed from 9.1 to 9.4.
9. **Declared performance:**

Essential characteristics	Performance	Harmonised technical specification
9.1 Self-closing ability	fulfilled, category 5 ($\leq 25N$)	5.4.2 und 5.1.2, EN 12209: 2003+AC:2006
9.2 Durability of self-closing action	fulfilled, category M (200.000 Z. / 25N)	5.3.1, EN 12209: 2003+AC:2006
9.3 Ability to maintain door in closed position and not contribute to the spread of fire	fulfilled, category 3 determined duration of fire resistance 30 minutes (PB-Nr.: 09/04-A103-B1 of 28.01.2010)	5.2.1 und 5.5, EN 12209: 2003+AC:2006
9.4 Control of dangerous substances	Not existing	5.1.1, EN 12209: 2003+AC:2006

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9. The declaration of performance is issued under the sole responsibility of the manufacturer identified point 4. Signed for and on behalf of the manufacturer by:

ppa. Rolf Allemann, Product Manager Locking Systems

Solothurn, 14.06.2013

