

## Declaration of Performance

LE/DoP-Nr. 045EN/CPR/2025-07-29

1. **Unique identification of the product type:** Mortise Locks  
12400, 12410, 12430, 12300, 12302, 12310, 12312, 12340, 12500, 12501, 12511, 12402, 12412, 12360, 12361
2. **Intended use:** Mechanically operated locks, on application with an appropriate door closing device, for application on fire and / or smoke control doors
3. **Manufacturer:** Glutz AG  
Segetzstrasse 13  
CH-4502 Solothurn  
Switzerland
4. **Authorised representative:** ./.
5. **Systems of assessment of constancy of performance:** System 1
6. **Harmonised standard:** DIN EN 12209:2004-03 + Berichtigung 1:2006-06
- Notified body:** PfB Rosenheim NB-Nr. 1644 as issued the Certificate of constancy of performance with the number 1644-CPR-057-24-002 to system 1 and essential characteristics assessed from 7.1 to 7.4.

### 7. Declared performance:

Essential characteristics	Performance	Harmonised technical specification
7.1 Self-closing ability	fulfilled, grade 5 (door mass up to 200kg, door closing force max.25N)	5.4.2 and 5.1.2 DIN EN 12209:2004-03 + Berichtigung 1:2006-06
7.2 Durability of self-closing action	fulfilled, grade M (200'000 cycles, 25N load on latch bolt)	5.3.1 DIN EN 12209:2004-03 + Berichtigung 1:2006-06
7.3 Ability to maintain door in closed position and not contribute to the spread of fi	Fulfilled, grade 1	5.2.1 and 5.5 DIN EN 12209:2004-03 + Berichtigung 1:2006-06
7.4 Control of dangerous substances	-	5.1.1 DIN EN 12209:2004-03 + Berichtigung 1:2006-06

8. The performance of the actual product is in conformity with the declared performance / performances. The issue of the declaration of performance complying with regulation (EU) nr. 305/2011 is under the sole responsibility of the above-named manufacturer.

Solothurn, 29.07.2025



Marco Hauri  
CEO



Stefan Häni  
Head of Development Mechanic