

# Declaration of Performance

LE/DoP-Nr. 045E/CPR/2021-04-06

- 1. Unique identification of the product type:** Mortise lock 12400  
Mortise lock 12410
- 2. Intended use:** Mechanically operated locks, on application with an appropriate door closing device, for application on fire and / or smoke control doors.
- 3. Manufacturer:** Glutz Ltd.  
Segetzstrasse 13  
CH-4502 Solothurn  
Switzerland
- 4. Authorised representative:** N/A
- 5. Systems of assessment of constancy of performance:** System 1
- 6. Harmonised standard:** EN 12209: 2003+AC:2006
- Notified body:** ift Rosenheim NB-Nr. 0757 has issued the Certificate of constancy of performance with the number 0757-CPR-230EG-6014391-2 to system 1 and essential characteristics assessed from 7.1 to 7.4.
- 7. Declared performance:**

Essential characteristics	Performance	Harmonised technical specification
<b>7.1</b> Self-closing ability	Fulfilled, grade 5 (door mass up to 200kg, door closing force max. 25N)	5.4.2 and 5.1.2, EN 12209: 2003+AC: 2006
<b>7.2</b> Durability of self-closing action	Fulfilled, grade M (200'000 cycles, 25N load on latch bolt)	5.3.1, EN 12209: 2003+AC: 2006
<b>7.3</b> Ability to maintain door in closed position and not contribute to the spread of fire	Fulfilled (EI 30; EI 90)	5.2.1 and 5.5, EN 12209: 2003+AC: 2006
<b>7.4</b> Control of dangerous substances	-	5.1.1, EN 12209: 2003+AC: 2006

- 8.** The performance of the actual product is in conformity with the declared performance / performances. The issue of the declaration of performance complying with regulation (EU) nr. 305/2011 is under the sole responsibility of the above-named manufacturer.

Signed for and on behalf of the manufacturer by:

ppa. Rolf Allemann, Product Manager Locks

Solothurn, 06.04.2021

